





TITLE
OUTLINE: BREAKER ASM

FIRST MADE FOR
 T1 & T12 Bkrs (BOB)

32B128001
 CONT ON SH 2
 SH 1

UNLESS OTHERWISE SPECIFIED, TOLERANCES ARE
 SURFACES 2 PL DEC ±
 ANGLES 3 PL DEC ±
 DEG

EMERGENCY OVERLOAD HANDLE, IF REQUIRED



- NOTES:
1. FOR MOUNTING HOLE DIMENSIONS, SEE PAGE A4-3, SKETCH "A"
 2. FOR CATALOG NUMBERS, SEE TABLE ON SHEET 2.
 3. "C" = 0.406 FOR 5, 10, AND 15 KVA MODELS.
 4. FOR 7561ZX9399 - "C" = 0.406
 5. FOR 7561ZH3899 - "C" = 0.625
 6. FOR 7561ZH4099 "C" = 0.406

REVISIONS	
21	N. Adams 06/27/11 Add Signal Light Column on Sh. 2 & 3 ECN B
2	STULPIN 07-MAR-01 ADD DIMS & NOTES; ADDED SHEET 2; ECN: NONE
3	GILLAND 07-AUG-01 ADD NOTE 4 ECNF727
4	GILLAND 29-MAY-03 ADD NOTE 5 ECN F903
5	N. Adams 2/11/05 Added BOB to (first made for)
17	N. Adams 4/13/06 Add 7561ZH4099 on sh. 3 ECN F992
18	N. Adams 8/08/06 Correct ZX3299 Add ZH3999 ECN F1004
19	N. Adams 9/07/06 Correct ID # 7561ZH2599, 2999 & 3099 ECN F1010
20	N. Adams 3/17/11 REMOVE NOTES 2,4,5,6 ECN B616

MADE BY: S. STULPIN 16-June-97
 ISSUED BY: Nicholas Adams 6/27/11

ECN #F198
 APPROVALS
 ECI
 32B128001
 SH 1

OUTLINE: BREAKER ON A BRACKET ASSEMBLY

FIRST MADE FOR

T1 & T12 BREAKERS (PROLEC)

Cat Number	Description	Voltage	ID	Trip Temp	Lead Length		Signal Light		Curve
					"A"	"D"	Emergency	Bulb Asm.	
7561ZH2099	10 KVA EC&S	120/240	2501K182G16	110	13	13	Y	Y	10
7561ZH2399	7.5 KVA EC&S	120/240	2501K182G59	110	13	13	Y	Y	7.5
7561ZH2499	37.5 KVA EC&S	120/240	2501K185G04	160	13	13	Y	Y	37.5
7561ZH2599	50 KVA EC&S	120/240	2501K185G05	160	8	13	Y	N	50
7561ZH2699	10 KVA EC&S	120/240	2501K182G03	150	8	15	Y	N	10
7561ZH2799	15 KVA EC&S	120/240	2501K182G04	153	8	15	Y	N	15
7561ZH2899	5 KVA EC&S	120/240	2501k182G64	120	13	13	Y	Y	5
7561ZH2999	7.5 KVA EC&S	120/240	2501K182G02	145	8	13	Y	N	7.5
7561ZH3099	50 KVA	120/240	2501K213G45	130	8	17	N	N	50
7561ZH3199	7.5 KVA	120/240	2501K212G09	110	13	13	N	N	7.5
7561ZH3299	10 KVA	120/240	2501K212G08	110	13	13	N	N	10
7561ZH3399	37.5 KVA	120/240	2501K213G09	110	13	13	N	N	37.5
7561ZH3499	10 KVA	120/240	2501K212G10	110	13	13	N	N	10
7561ZH3599	50 KVA	120/240	2501K213G09	110	8	17	N	N	50
7561ZH3699	25 KVA	120/240	2501K212G11	120	13	13	N	N	25
7561ZH3899	50 KVA	120/240	2501K185G51	160	9	15	Y	N	50
7561ZH3999	15 KVA EC&S	120/240	2501K182G69	110	13	13	Y	Y	15
7561ZH4099	25 KVA EC&S	120/240	2501K185G06	160	8	15	Y	N	25
7561ZH4899	37.5 KVA	120/240	2501K185G53	160	13	13	Y	N	37.5
7561ZH4999	50 KVA	120/240	2501K185G54	160	13	13	Y	N	50
7561ZH5299	50 KVA	120/240	2501K185G02	160	6T	6T	Y	Y	50
7561ZH6099	5 KVA	120/240	2501K182G01	145	6	6	Y	Y	5
7561ZH6199	10 KVA	120/240	2501K182G03	150	6	6	Y	Y	10
7561ZH6299	25 KVA	120/240	2501K182G05	160	6	6	Y	Y	25
7561ZH6399	50 KVA	120/240	2501K185G05	160	6	6	Y	Y	50
7561ZH6499	37.5 KVA	120/240	2501K185G04	160	6	6	Y	Y	37.5
7561ZH8099	25 KVA	120/240	2501K182G05	160	13	13	Y	N	25
7561ZH8199	25 KVA	120/240	2501K182G57	110	8	15	Y	N	25
7561ZX0299	25KVA EC&S	120/240	2501K182G57	110	13	13	Y	Y	25
7561ZX0399	25 KVA	120/240	2501K182G39	140	6T	6T	Y	Y	25
7561ZX0499	37.5 KVA	120/240	2501K185G15	148	6T	6T	Y	Y	37.5
7561ZX0599	10 KVA	120/240	2501K182G03	150	12	9	Y	Y	10
7561ZX0699	15 KVA	120/240	2501K182G04	153	12	9	Y	Y	15
7561ZX0799	25 KVA	120/240	2501K182G05	160	12	9	Y	Y	25
7561ZX0899	37.5 KVA	120/240	2501K185G52	148	13	13	Y	Y	37.5
7561ZX0999	50 KVA	120/240	2501K185G17	130	6T	6T	Y	Y	50
7561ZX1099	37.5 KVA EC&S	120/240	2501K185G18	110	13	13	Y	Y	37.5
7561ZX1199	50 KVA EC&S	120/240	2501K185G19	110	8	8	Y	Y	50
7561ZX1299	5 KVA EC&S	120/240	2501K182G44	110	13	13	Y	Y	5
7561ZX1399	10 KVA EC&S	120/240	2501K182G08	130	13	13	Y	Y	10
7561ZX1499	25 KVA EC&S	120/240	2501K182G54	130	13	13	Y	Y	25
7561ZX1799	15 KVA EC&S	120/240	2501K182G23	130	13	13	Y	Y	15

REVISION

18) N. Adams 8/08/06 Correct ZX3299 & Add ZH3999 ECN: F1004	19) N, Adams 09/07/06 Correct ID # 7561ZH2599, ___2999 & ___3099	20) N. Adams 3/17/11 Remove notes 2, 4, 5, 6 ECN: B616	21) N. Adams 6/29/11 Add Signal Light Asm. and sheet 4. ECN: B
-------------------------------------------------------------------	------------------------------------------------------------------------	--------------------------------------------------------------	----------------------------------------------------------------------

MADE BY: R. GILLAND 9-OCT-01	APPROVAL	ECI	DRAWING NO. 3 2B128001
ISSUED BY: Nicholas Adams 06/29/11			

OUTLINE: BREAKER ON A BRACKET ASSEMBLY

FIRST MADE FOR

T1 & T12 BREAKERS (PROLEC)

Cat Number	Description	Voltage	ID	Trip Temp	Lead Length		Signal Light		Curve
					"A"	"D"	Emergency	Bulb Asm.	
7561ZX1899	50 KVA EC&S	120/240	2501K185G19	110	8	8	Y	Y	50
7561ZX1999	25 KVA EC&S	120/240	2501K182G55	120	13	13	Y	Y	25
7561ZX2099	15 KVA EC&S	120/240	2501K182G04	153	13	13	Y	Y	15
7561ZX2199	15 KVA EC&S	120/240	2501K182G38	120	13	13	Y	Y	15
7561ZX2299	5 KVA	120/240	2501K182G15	110	6T	6T	Y	Y	5
7561ZX2399	5 KVA EC&S	120/240	2501K182G58	150	13	13	Y	Y	5
7561ZX2499	10 KVA EC&S	120/240	2501K182G03	150	13	13	Y	Y	10
7561ZX2599	15 KVA EC&S	120/240	2501K182G04	153	13	13	Y	Y	15
7561ZX2699	25KVA EC&S	120/240	2501K182G05	160	13	13	V	Y	25
7561ZX2899	25 KVA	120/240	2501K182G12	160	6T	6T	Y	Y	25
7561ZX2999	37.5 KVA EC&S	120/240	2501K185G22	140	8	8	Y	Y	37.5
7561ZX3099	50 KVA EC&S	120/240	2501K185G13	120	13	13	Y	Y	50
7561ZX3199	10 KVA EC&S	120/240	2501K182G13	120	13	13	Y	Y	10
7561ZX3299	10 KVA EC&S	120/240	2501K182G45	110	13	13	Y	Y	10
7561ZX3399	15 KVA EC&S	120/240	2501K182G51	140	13	13	Y	Y	15
7561ZX3499	37.5 KVA EC&S	120/240	2501K185G24	120	13	13	Y	Y	37.5
7561ZX3599	50 KVA EC&S	120/240	2501K185G23	130	13	13	Y	Y	50
7561ZX5299	50 KVA EC&S	120/240	2501K185G46	110	13	13	Y	Y	50
7561ZX5399	37.5 KVA EC&S	120/240	2501K185G47	130	13	13	Y	Y	37.5
7561ZX5599	50 KVA EC&S	120/240	2501K185G51	160	13	13	Y	Y	50
7561ZX5699	37.5 KVA	120/240	2501K185G01	160	6T	6T	Y	Y	37.5
7561ZX5799	50 KVA	120/240	2501K213G02	160	6T	6T	N	N	50
7561ZX5899	15 KVA	120/240	2501K212G03	150	6	6	N	N	15
7561ZX5999	50 KVA	120/240	2501K185G05	160	13	13	Y	N	50
7561ZX6099	15 KVA	120/240	2501K212G04	153	13	13	N	N	15
7561ZX6199	25 KVA	120/240	2501K182G05	160	13	13	Y	N	25
7561ZX6299	15 KVA	120/240	2501K182G03	150	13	13	Y	N	15
7561ZX6399	37.5 KVA EC&S	120/240	2501K185G04	160	13	13	Y	Y	37.5
7561ZX6499	15 KVA	120/240	2501K182G04	153	13	13	Y	N	15
7561ZX6599	37.5 KVA	120/240	2501K185G04	160	13	13	Y	N	37.5
7561ZX6699	50 KVA	120/240	2501K185G05	160	13	13	Y	N	50
7561ZX6799	15 KVA	120/240	2501K182G45	110	8	14	Y	Y	15
7561ZX6899	15 KVA	120/240	2501K182G38	120	8	14	Y	Y	15
7561ZX6999	25 KVA	120/240	2501K182G72	130	8	15	Y	Y	25
7561ZX7099	50 KVA	120/240	2501K185G23	130	8	16	Y	Y	50
7561ZX7199	25 KVA	120/240	2501K182G55	120	8	15	Y	Y	25
7561ZX7299	10 KVA EC&S	120/240	2501K182G03	150	13	13	Y	Y	10
7561ZX7399	10 KVA	120/240	2501K212G03	150	13	13	N	N	10
7561ZX7499	25 KVA	120/240	2501K182G57	110	15	15	Y	Y	25
7561ZX7699	25 KVA EC&S	120/240	2501K182G05	160	13	13	Y	Y	25
7561ZX7799	25 KVA	120/240	2501K212G05	160	13	13	N	N	25
7561ZX7899	25 KVA	240/480	2501K182G70	140	8	15	Y	Y	10
7561ZX7999	37.5 KVA	240/480	2501K182G04	153	8	16	Y	Y	15
7561ZX8099	50 KVA	240/480	2501K185G55	148	8	17	Y	Y	25
7561ZX8199	50 KVA	120/240	2501K213G05	160	13	13	N	N	50

REVISION

18) N. Adams 8/08/06 Correct ZX3299 & Add ZH3999 ECN: F1004	19) N, Adams 09/07/06 Correct ID # 7561ZH2599, __2999 & __3099	20) N. Adams 3/17/11 Remove notes 2, 4, 5, 6 ECN: B616	21) N. Adams 6/29/11 Add Signal Light Asm. and sheet 4. ECN: B
-------------------------------------------------------------------	----------------------------------------------------------------------	--------------------------------------------------------------	----------------------------------------------------------------------

MADE BY: R. GILLAND 9-OCT-02	APPROVAL	ECI	DRAWING NO. 3 2B128001
ISSUED BY: Nicholas Adams 06/29/11			

OUTLINE: BREAKER ON A BRACKET ASSEMBLY

FIRST MADE FOR T1 & T12 BREAKERS (PROLEC)

Cat Number	Description	Voltage	ID	Trip Temp	Lead Length		Signal Light	Signal Light	Curve
					"A"	"D"	Emergency	Bulb Asm.	
7561ZX8299	10 KVA	120/240	2501K182G45	110	14	19	Y	Y	10
7561ZX8399	15 KVA	120/240	2501G182G69	110	14	19	Y	Y	15
7561ZX8499	10 KVA	120/240	2501K212G33	120	8	13	N	N	10
7561ZX8599	25 KVA	120/240	2501K212G34	120	8	13	N	N	25
7561ZX8699	50 KVA	120/240	2501K213G45	130	8	15	N	N	50
7561ZX8799	25 KVA	120/240	2501K182G57	110	14	20	Y	Y	25
7561ZX8899	37.5 KVA	120/240	2501K185G18	110	14	21	Y	Y	37.5
7561ZX8999	5 KVA EC&S	120/240	2501K182G44	110	13	13	Y	Y	5
7561ZX9199	50 KVA EC&S	120/240	2501K185G23	130	8	17	Y	Y	50
7561ZX9299	50 KVA EC&S	120/240	2501K185G51	160	8	15	Y	N	50
7561ZX9399	25 KVA EC&S	120/240	2501K182G05	160	8	15	Y	N	25
7561ZX9499	7.5 KVA EC&S	120/240	2501K182G59	120	13	13	Y	Y	7.5
7561ZX9599	37.5 KVA EC&S	120/240	2501K185G04	160	8	15	Y	N	37.5
7561ZX9899	25 KVA	120/240	2501K182G57	110	14	21	Y	Y	25

REVISION

18) N. Adams 8/08/06 Correct ZX3299 & Add ZH3999 ECN: F1004	19) N. Adams 09/07/06 Correct ID # 7561ZH2599, __2999 & __3099	20) N. Adams 3/17/11 Remove notes 2, 4, 5, 6 ECN: B616	21) N. Adams 6/29/11 Add Signal Light Asm. and sheet 4. ECN: B
-------------------------------------------------------------------	----------------------------------------------------------------------	--------------------------------------------------------------	----------------------------------------------------------------------

MADE BY: R. GILLAND 9-OCT-02	APPROVAL	ECI	DRAWING NO.
ISSUED BY: Nicholas Adams 06/29/11			3 2B128001

Bracket Mounted T1/T12 Circuit Breaker Installation.

These instructions apply to bracket mounted T1 and T12 circuit breakers with and without emergency overload features.

With Emergency Overload

1. To prepare for installation remove the bracket mounted breaker and it's associated operating handle from it's packaging making sure that the operating handle shipped with the particular breaker stays with it. Adjustment will be lost if this is not adhered to. Remove the mounting nut from the operating handle and remove the cotter pin from the emergency overload arm assembly and slide the assembly off the shaft. The kit is now ready for installation.
2. Insert the breaker/bracket into the transformer tank and align the mounting hole with the hole in the tank wall. Insert the operating handle through the hole in the tank wall and the hole in the bracket The center depression on the circumference of the operating detail must fit over the protrusions in the tank wall and bracket mounting holes. Install the mounting nut and tighten. Torque to 200- 250 inch pounds.
3. Move the emergency lever on the breaker to the normal position. (All the way to the left when looking down into the tank) . Move the emergency overload lever on the operating detail as far as it will go in an clockwise direction.
4. Slide the emergency overload arm assembly onto the shaft taking care that the roll pin on the breaker overload lever is in the slot in the arm. Line up the holes in the bushing on the arm assembly with the hole in the shaft and insert the cotter pin.
5. Install the meter seal.
6. Attach the operating rod which has been pre assembled to the circuit breaker to the bent shaft of the operating detail with the cotter pin. Secure cotter pin.

Mechanical installation is now complete.

Without Emergency Overload.

1. To prepare for installation remove the bracket mounted breaker and its associated operating handle from it's packaging making sure that the operating handle shipped with the particular breaker stays with it. Adjustment will be lost if this is not adhered to. Remove the mounting nut from the operating handle. This kit is now ready for installation.
2. Insert the breaker/bracket into the transformer tank and align the mounting hole with the hole in the tank wall. Insert the operating handle through the hole in the tank wall and the hole in the bracket The center depression on the circumference of the operating detail must fit over the protrusions in the tank wall and bracket mounting holes. Install the mounting nut and tighten. Torque to 200- 250 inch pounds.
3. Attach the operating rod which has been pre assembled to the circuit breaker to the bent shaft of the operating detail with the cotter pin. Secure cotter pin.

Mechanical installation is now complete.