Anti-Tracking Kit



brass grommet.

ECI, ERMCO Components Inc. 1607 Industrial Road Greeneville, TN 37745 Phone: (423) 638-2302 Toll Free: (877) 267-1855 Fax (423) 636-6492




General Information


Tintroduces the bushing ▲Anti-Tracking Kit for use on Distribution Transformer high voltage bushings in contaminated areas. Installation of the Anti-Tracking Kit is performed by placing the small spring around the bushing top casting between the casting and the porcelain making sure it touches both. The larger spring is then placed around the lower porcelain touching both the porcelain and the tank cover. The grommet on the loose end attached to the bottom spring should be tightly attached to the tank ground nut. The springs used in the Anti-Tracking Kit are 302 stainless with a nickel plated

BEYOND THE STANDARD

Tank ground nut



| Catalog Number | Description |
|----------------|--------------------------|
| 7590ZA0199 | Anti-tracking kit |
| | (Large and small spring) |



For more information about Anti-Tracking Kits, contact your Ermco Components representative or call (877) 267-1855